




FIXING DETAILS

DESIGN WIND PRESSURE.

SPAN	600	900	1200	1500	1800
DESIGN WIND PRESSURE	6.1	4.0	3.0	2.4	2.0



SundeK Mk II Fixing Strap








SundeK 500 Finishing Clip

NOTE:- SUNDEK MK II FIXING STRAP TO BE USED FOR GENERAL FIXING OF DECK.
SUNDEK MK II FINISHING CLIP TO BE USED AT THE END OF A RUN.

MATS: 1.20mm BASE METAL THICKNESS Zn COATED STEEL TO AS 1445-G300-Z275

RECOMMENDED FASTENERS.

SUPPORT MEMBER	NORMAL FASTENER	OVER INSULATION UP TO 100mm THICK	FASTENERS PER CLIP	TYPE
STEEL 1.6 TO 2.5mm THICK	Nº 10-16 x 16 WAFER HEAD SELF DRILL & TAP SCREW	Nº 10-16 x 22 WAFER HEAD SELF DRILL & TAP SCREW	2	
STEEL 2.5 TO 5.0mm THICK	Nº 10-24 x 16 WAFER HEAD SELF DRILL & TAP SCREW	Nº 10-24 x 22 WAFER HEAD SELF DRILL & TAP SCREW	2	
STEEL OVER 5.0mm THICK	Nº 10-24 x 16 WAFER HEAD THREAD CUTTING SCREW DRILL Ø4.5mm	REFER TO MONIER OFFICE FOR RECOMMENDATION	2	
HARDWOOD	50 x 3.75 C'SK HEAD GALV. SPIRAL NAIL, OR Nº 10-12 x 25 WAFER HEAD TYPE 17. WOODSCREW	60 x 3.75 C'SK HEAD GALV. SPIRAL NAIL, OR Nº 10-12 x 45 WAFER HEAD TYPE 17. WOODSCREW	2	
	SOFTWOOD	Nº 10-12 x 45 WAFER HEAD TYPE 17. WOODSCREW	2	

MANUFACTURER:- MONIER METAL BUILDING PRODUCTS EVERLEY ROAD SOUTH GRANVILLE N.S.W. 2142.	FIXING OF:- <u>MONIER SUNDEK.</u> ON BUILDINGS OF HEIGHT UP TO 10m DESIGN DATA SHEET DARWIN CYCLONIC AREA
CERTIFIED:-  ERIC STOKES BCC FIC (AUST) HEAD OF DEPARTMENT CIVIL & AERONAUTICAL ENGINEERING R.M.I.T. Ltd.	DEPARTMENT OF LANDS BUILDING BRANCH DRAWING NO. M/112/6
DATE: 9-12-1985	APP'D:  DATE 11-12-85 C. CHEW MIE(AUST)