


FIXING DETAILS

DESIGN WIND PRESSURE.

SPAN	600	900	1200	1500	1800
DESIGN WIND PRESSURE	6.1	4.0	3.0	2.4	2.0



Sundeck Mk II Fixing Strap



Sundeck 500 Finishing Clip

NOTE:- SUNDECK MK II FIXING STRAP TO BE USED FOR GENERAL FIXING OF DECK.
 SUNDECK MK II FINISHING CLIP TO BE USED AT THE END OF A RUN.
 MATS: 1.20mm BASE METAL THICKNESS Z_n COATED STEEL TO AS 1445-G300-Z275.

RECOMMENDED FASTENERS.

SUPPORT MEMBER	NORMAL FASTENER	OVER INSULATION UP TO 100mm THICK	FASTENERS PER CLIP	TYPE
STEEL 1.6 TO 2.5mm THICK	Nº 10-16 x 16 WAFER HEAD SELF DRILL & TAP SCREW	Nº 10-16 x 22 WAFER HEAD SELF DRILL & TAP SCREW	2	
STEEL 2.5 TO 5.0mm THICK	Nº 10-24 x 16 WAFER HEAD SELF DRILL & TAP SCREW	Nº 10-24 x 22 WAFER HEAD SELF DRILL & TAP SCREW	2	
STEEL OVER 5.0mm THICK	Nº 10-24 x 16 WAFER HEAD THREAD CUTTING SCREW DRILL Ø4-5mm	REFER TO MONIER OFFICE FOR RECOMMENDATION	2	
HARDWOOD	50 x 3.75 C'SK HEAD CALV. SPIRAL NAIL, OR Nº 10-12 x 25 WAFER HEAD TYPE 17 WOODSCREW	60 x 3.75 C'SK HEAD CALV. SPIRAL NAIL, OR Nº 10-12 x 45 WAFER HEAD TYPE 17 WOODSCREW	2	
SOFTWOOD	Nº 10-12 x 45 WAFER HEAD TYPE 17 WOODSCREW	Nº 10-12 x 45 WAFER HEAD TYPE 17 WOODSCREW	2	

MANUFACTURER:- WOODROFFE SHEET METAL Pty. Ltd. 1 TAMINGA St. REGENCY PARK. S.A. 5010	FIXING OF:- <u>MONIER SUNDEK.</u> ON BUILDINGS OF HEIGHT UP TO 10m
CERTIFIED: ERIC STOKES BCC PIC (AUST) HEAD OF DEPARTMENT CIVIL & AERONAUTICAL ENGINEERING P.M. 17 LTD	DESIGN DATA SHEET DARWIN CYCLONIC AREA
DATE:- 9-12-1985	DEPARTMENT OF LANDS BUILDING BRANCH APR 30 9 16 30 AM '86 MIE (AUST)
	DRAWING NO. M/113/6