


SERVICE ACCESS  
600 mm

BASIC ENVELOPE SIZES

2320

ALL SERVICES CONNECT TO THIS END




ALTERNATIVE OPTION

WARNING  
 Product Approval Withdrawn  
 April 2012

SOLAHART PTY. LTD. 426 STUART HIGHWAY WINNELLIE DARWIN. N.T. PH.(089) 84-4959

NOTES



LATITUDES BELOW 15°  
PERMISSIBLE VARIATION TO  
NORTHERLY DIRECTION

- 1 FOR INSTALLATIONS WITHIN 15° OF THE EQUATOR, NORTHERLY OR SOUTHERLY ASPECTS ARE EQUALLY SATISFACTORY
- 2 LOCATE UNIT CENTRALLY OVER ROOF TRUSS OR DIVIDING WALL ROOF STRUT WHERE POSSIBLE MAX CENTERS OF UNDER PURLINS 2400mm, TRIMS 1800mm
- 3 INSTALL UNIT AS CLOSE AS POSSIBLE TO MOST FREQUENTLY USED HOT WATER TAP
4. ENSURE COLLECTORS ARE NOT LEFT EXPOSED TO SUN WHEN NOT FILLED WITH WATER OR GLASS BREAKAGE MAY OCCUR.

	OPERATING WEIGHTS KG (LBS)	
	300L	160L
ABSORBERS	96 (211)	48 (106)
TANK	373 (820)	205 (451)
TOTAL	469 (1031)	253 (557)

Colless & Associates Pty. Ltd.

Consulting Engineers  
Darwin N.T. (089) 819644

FIXING FOR SOLAHART 300 LITRE  
H.W. HEATERS WITH PITCH ROOFS.

DESIGN DATA SHEET.

Certified T. Chell  
Date 31-7-84

DARWIN CYCLONE AREA.  
APP'D [Signature] DATE 31-7-84

DWG. N°  
M/503/1A