

CORRUGATED — SPAN TABLES.

.49 STEEL, SCREWS + NEOS + CAPS. 10 FIXINGS/SHEET

BUILDINGS UP TO 5m.

TERRAIN FACTOR	ROOF AREA LOCATION	WORKING PRESSURE (kPa)	MAXIMUM CONTINUOUS SPANS (mm)	MAXIMUM END SPANS (mm)	MAXIMUM OVERHANGS	
					*Unstiffened (mm)	*Stiffened (mm)
CATEGORY 1. 1.02	D	4.24	1295	1028	100	200
	F	5.37	1098	876	100	200
	G	6.49	894	745	100	150
CATEGORY 2. 0.93	D	3.53	1413	1126	100	200
	F	4.46	1259	997	100	200
	G	5.40	1092	872	100	200
CATEGORY 2.5 0.79	D	2.55	1500	1280	100	200
	F	3.22	1364	1169	100	200
	G	3.89	1253	1076	100	200

*STIFFENED/UNSTIFFENED REFERS TO WHETHER OR NOT THE EDGE OF THE SHEETING HAS BEEN STIFFENED BY A GUTTER SYSTEM.

CORRUGATED

.49 STEEL, SCREWS + NEOS + CAPS. 10 FIXINGS/SHEET.

BUILDINGS 5 — 10m HIGH

TERRAIN FACTOR	ROOF AREA LOCATION	WORKING PRESSURE (kPa)	MAXIMUM CONTINUOUS SPANS (mm)	MAXIMUM END SPANS (mm)	MAXIMUM OVERHANGS	
					*Unstiffened (mm)	*Stiffened (mm)
CATEGORY 1. 1.09	D	4.85	1194	943	100	200
	F	5.31	956	787	100	150
	G	7.41	809	638	100	150
CATEGORY 2. 1.00	D	4.08	1322	1050	100	200
	F	5.16	1137	900	100	200
	G	6.24	935	774	100	150
CATEGORY 2.5 0.85	D	2.94	1513	1211	100	200
	F	3.72	1381	1100	100	200
	G	4.50	1253	992	100	200

Enquiries and further information available from: HANDFORD INDUSTRIES DARWIN (089) 81 2218
HANDFORD INDUSTRIES BRISBANE (07) 265 2999

DESIGN DATA SHEET Northern Territory Cyclonic Areas

Manufacturer:
HANDFORD INDUSTRIES PTY. LTD.
Phone No. 265 0443

Address:
19 PRITCHARD ROAD, VIRGINIA,
BRISBANE, Q. P.O. BOX 157 NUNDAH. 4012.

Certified *David Handford* MIE (Aust)
Date *22/10/81*

Subject: Fixing, in the Darwin area of
CORRUGATED

Approved *Richard M. I.E. (Aust)*
Date *30 October 1981*

DRG No. M/103/14