



1. ENCLOSURE TO BE TOTALLY ENCLOSED WEATHERPROOF CUBICLE. ZINC COATED STEEL, POWDER COATED TO COLOUR PEBBLE GREY.
2. MOUNT MSB ON A MOUNTING FRAME ON A 200mm THICK N25 CONCRETE PLINTH.
3. PROVIDE SUPPLY AUTHORITY APPROVED LOCKING TO RETAILER METERING SECTION.
4. WHEN METERING IS NOT REQUIRED, THE PWC PWC METER BASE IS TO BE BRIDGED OUT USING REMOVABLE COPPER LINKS WITHIN A SUPPLY AUTHORITY APPROVED AND SEALABLE ENCLOSURE AND MOUNTED BEHIND THE ESCUTCHEON PANEL.
5. PROVIDE PADLOCKABLE HANDLE WITH STREET OWNER PADLOCK.
6. ALL CONTROL CABLES TO BE 4mm² Cu PVC.

0	ISSUED AS A STANDARD DRAWING	AUG 2020	CJ	AF
No.	DESCRIPTION	DATE	INIT.	DEPT/COMPANY.
AMENDMENTS				

 Northern Territory
Government

SUBDIVISION DEVELOPMENT GUIDELINES STANDARD DRAWINGS					
LIGHTING					
MSB WITH NO TIME CONTROL WIRING DIAGRAM AND DETAILS					
WIRING DIAGRAM AND TYPICAL DETAILS					
NTG PROJECT No. -	NTG ASSET No. -	SHEET No. 16 OF 16	NTG DRAWING No. SS5015	AMENDMENT 0	SHEET SIZE A1